Laboratories GSD SRL

CE MARKING

*ELECTROMAGNETIC COMPATIBILITY*
*ELECTRICAL SAFETY*
*LASER SPECTROSCOPY*
*ENVIRONMENTAL PHYSICS*

**G.S.D. S.r.l.**
Certified in accordance with
**UNI EN ISO 9001:2015**
by
**TÜV Rheinland Italia S.r.l.**
**Certificate N. 39 00 1850509**

| **G.S.D. Srl PISA - Italy** | ***Attestation of Conformity n. 19486-UF*** | Rev. 00 |
|---|---|---|
| | | |
| **Manufacturer** | **UR FOG S.r.l.** | |
| Address | Via Giacinto Collegno, 11<br>10143 TORINO<br>Italy | |
| **Product** | **Modular 500** | |
| **Product Family** | **Modular 200, Modular 300, Modular 400, Modular 800** | |
| | | |
| **Testing Laboratory** | **G.S.D. S.r.l.** | |
| Address | Via Marmiceto, 8<br>56121 Ospedaletto Pisa (PI)<br>Italy | |
| **Test specification** | Electromagnetic Compatibility<br>- EN 61000-3-3: 2013 + /A1:2018<br>- EN 61000-3-2:2014<br>- EN 50130-4:2011 +/A1:2014 Environmental Classification: Class II<br>Electrical Safety Verifications<br>- EN 60065:2014 + A11:2017<br>Test does not include on-site installation, service and maintenance | |
| **Ref. documents** | GSD project n. 19486 | |
| **Comments and Conclusions** | During October 18-29, 2019 we have performed test in accordance to the above listed and referenced standards<br>The test item has fulfilled all the requirements without remarks.<br>The product comply with European standard according to the test specification. | |
| | | |
| | | |
| **Location and Date of Issue** | Pisa, 2019 October 29 | |

G.S.D. s.r.l.
Via Marmiceto, 8
56121 OSPEDALETTO - PISA
Tel. 050.984254 - Fax 050.984262
P. IVA 01343950505

SENIOR EMC TEST MANAGER
*Dr. Gian Luca Genovesi*

QUALITY MANAGER
*Dr. David Pelliccia*

*This document may be only fully reproduced.*
*Every partial reproduction is only allowed after written approval released by G.S.D. S.r.l.*